

QUOTATION SC 622/2009

SPECIFICATION FOR GENERATORS

The following generators are required for an Eskom shutdown on Sunday, 17th May 2009, from 06h00 to 19h00.

Generators required:

2 x 300 KVA

2 x 100 KVA

1 x 69 KVA

3 x 34 KVA

The quotation must make allowance for the following:

Generators are to be delivered to the sites by Friday, 15/5/2009, by 16h00 at the latest.

This is to accommodate a dummy run on Saturday, 16/5/2009.

Generators must be collected on 18/5/2009 from the sites, from 8am onwards.

Suppliers must have spare generators and cable, should the need arise for a replacement.

Quotations are to include for a 15 metre length of trailing cable, sized for the relevant generator.

Generators are to be delivered to the sites with a full tank of diesel.

Overstrand Municipality will ensure that the diesel tanks are filled before the generators are collected.

The quotation is to include for a technician to be on standby, should one of the generators fail. The technician will make the necessary arrangements to replace faulty generators should the need arise.

If suppliers do not have the size of generators required, they are to price for a larger unit.

The generators will be placed at unmanned sites.

The quotation is to include for security arrangements, suitable toilet arrangements and protection from inclement weather for security staff.

Suppliers are to indicate on their quotation whether they are going to supply security for the sites, or not.

Suppliers are to note that the shutdown may be cancelled due to inclement weather and that an alternative date will be supplied by Eskom.

The quotation is to be valid for this alternative date as well. As soon as this alternative date becomes available it will be communicated to the prospective supplier.

