



QUOTATION SC 666/2009: SUPPLY AND INSTALLATION OF AIR CONDITIONERS IN MUNICIPAL OFFICES AT ONRUS RIVER

Specifications:

1. Quotations are invited for the installation of air conditioners at the Overstrand Municipality's offices in Onrus River, c/o Viljoen & Molteno Streets, Onrus River.
2. Air conditioners to be supplied are to be **LG or similar** and are listed as follows :
 - 1 x 24 000 BTU split unit heating and cooling function for the boardroom
 - 1 x 18 000 BTU split unit heating and cooling function for office
 - 1 x 9 000 BTU split unit heating and cooling function for office
 - 6 x 12 000 BTU split unit heating and cooling function for offices

Each air conditioning unit is to be priced separately and is to include the price of the electrical connection, where applicable.

3. A layout plan of the building is attached to this specification. The air conditioning units are required for the rooms marked 1 to 9 on the plan.
4. The prospective tenderer must ascertain whether there are electrical connections for the units that are to be installed.
5. Where electrical connections already exist, they are to be reconfigured at the main switchboard so that the electrical load is evenly spread over all three phases.
6. All existing connections must comply with the latest wiring code SANS 10142.
7. Where there are no electrical connections for the air conditioning units, the prospective bidder must allow for the installation of such in his bid.
8. The wiring is to be installed in appropriately sized white trunking and terminated in a 4x4 wonder box with a 50amp double pole isolator.

9. Each air conditioning unit circuit is to be protected at the main switchboard by a 20amp miniature circuit breaker.
10. The load is to be spread over all three phases.
11. All new installations must comply with the latest wiring code, i.e. SANS 10142.
12. A compulsory site inspection will be held on Friday 29 May 2009 at 10:00 in the Boardroom of the Overstrand Municipality's offices at c/o Viljoen & Molteno Streets, Onrus River.
13. All the works, including repairs to plastering and painting of walls to the original standard and to the satisfaction of the client, must be completed by no later than 30 June 2009.
- 14. Bidders must have a CIDB rating of at least 1ME.**
15. A Certificate of Compliance (CoC) must be provided by the successful bidder on completion of all electrical works.
16. A pricing schedule is attached to this specification, and is to be completed in full by bidders.
17. For any enquiries, please contact Mr Peter Burger at 028 – 313 8084.

Please note: Tenders solicited in terms of a quotation procedure:

Clause number F.2.1 is applicable: Only those tenderers who are registered with the CIDB, or are capable of being so prior to the evaluation of submissions, in a 1ME or higher class of construction work, are eligible to have their tenders evaluated.